



Dated: 7/103/2026

No. 6/DFS/MS/SZ/2026/ 78

To,

The Executive Engineer,
CPWD, IIT Campus,
New Delhi-110016.

Subject: - Regarding issuance of Fire Safety Certificate in r/o New Academic building for National University of Education Planning and Administration at 17-B, Sri Aurobindo Marg, New Delhi-110016.

Sir,

Please refer to your application dated 16.01.2026, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 03/03/2026 in the presence of Mr. Nadeem Faisal, AE(Civil) & Mr. Satyapal , AE(E) and observed that building comprised of Basement + Ground, + 05 upper floor.

Following shortcomings were observed during time of inspection:

1. Fire Check door not provided in basement.
2. MOEFA not provided in basement.
3. Pressurization in lift and staircases are not provided.
4. Terrace pump of capacity 900 LPM is not provided.
5. Exit signage and lift signage not provided.

In view of above shortcomings, the case for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Owner/Occupier, Academic Building at NUEPA Campus 17-B, Sri Aurobindo Marg, New Delhi-110016.