



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026011500314

Dated: 15-05-2026

SHORTCOMING(S)

With reference to your application ID **52026011500314** dated **15-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sarvodaya Kanya Vidyalaya** at **SKV West Patel Nagar, New Delhi-05** from fire safety point of view in presence of **Paramjeet Singh, Estate Manager** on dated **24/04/2026** During the course of inspection following observations were made:-

1. One stair found in block- B & block- D against requirement of two staircases having width of 1.50 mtrs. each.
2. First Aid hose reels found provided but not functional.
3. Terrace fire pumps capacity of 450 LPM (02 nos.) found provided but not functional in A block.
4. Overhead water tank in Block A & B of capacity 10,000 liters exclusively for firefighting capacity found removed.
5. Exit Signs found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. SEEMA SRIVASTAVA , SKV West Patel Nagar, patel nagar, WEST A, WEST PATEL NAGAR, 110008
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.