



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026012200508

Dated: 27-05-2026

SHORTCOMING(S)

With reference to your application ID **52026012200508** dated **27-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Hostel Block of Sri Moolchand Kharati Ram Hospital** at **Lajpat Nagar-III, New Delhi-110024** from fire safety point of view in presence of **Sulagno Basu** on dated **07/05/2026** During the course of inspection following observations were made:-

- 1.First-Aid-Hose Reel provided but found nonfunctional.
- 2.Internal and Yard Hydrants provided but found non functional.
- 3.Pumping's Arrangements provided but found non functional.
- 4.Exit & floors Signage's not provided in strategic location in the building

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. Sulagno Basu , Moolchand Hospital, Lajpat Nagar, New Delhi, Delhi, 110024
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.