



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026012800620

Dated: 22-05-2026

SHORTCOMING(S)

With reference to your application ID **52026012800620** dated **22-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **MCD Primary Co. ed. Pratibha School** at **Jagat Pur, Delhi** from fire safety point of view in presence of **Sh. Naveen** on dated **14/05/2026** During the course of inspection following observations were made:-

1. The Gate width is 2.58 m against requirement of 4.5 m
2. 01 no. staircase is 1.39 m provided against required 2 nos. staircase of 1.50 m each
3. First-aid hose reel is not provided.
4. Fire pump of 450 LPM capacity is not provided.
5. Overhead water storage tank of 10,000 ltrs. capacity is not provided
6. Exit signages are not provided

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-

1. Naveen Kumar Mishra , MCP Co-ed School, Gali No. 5, Jagatpur, Delhi, 110084
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.