



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026030801462

Dated: 22-05-2026

SHORTCOMING(S)

With reference to your application ID **52026030801462** dated **22-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Fun Melon Kids Gym** at **Basement, 6, Bhama Shah Marg, Opp. Kirpal Bagh Ashram, Near Model Town, Delhi-110009** from fire safety point of view in presence of **Sh. Tarun** on dated **14/05/2026** During the course of inspection following observations were made:-

1. Approved fire check door of requisite fire resistance rating shall be provided for proper segregation between the basement and upper floor guest house occupancy, in accordance with fire and life safety requirements.
2. Fire extinguishers are found inadequate in numbers; therefore, additional fire extinguishers of suitable type and capacity shall be provided in accordance with the occupancy hazard and relevant fire safety provisions.
3. First-aid hose reel hose found non-functional.
4. MOEFA found non-functional.
5. Automatic sprinkler system found non-functional.
6. Fire pumps of 1600 LPM & 900 LPM found removed.
7. Overhead water storage tank of 10,000 ltrs capacity is provided against the requirement of 20,000 ltrs. capacity.
8. Exit signages with proper illumination and directional indication shall be provided at all required locations for safe evacuation during emergency conditions.
9. Kitchen activities being carried out in the basement, where kids gaming activities are taking place, shall be discontinued and shifted to an appropriate floor/area as per fire safety norms.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-

1. Ramdhan Gupta , 45-A Vivek, Mall Road, Civil Line, Mall Road, 110054
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.