



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026031801696

Dated: 02-06-2026

SHORTCOMING(S)

With reference to your application ID **52026031801696** dated **02-06-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Ideal Public School** at **Gali No. 2, B-Block, Swaroop Vihar, Delhi-110034** from fire safety point of view in presence of **Ms. Karnika, Principal** on dated **25/05/2026** During the course of inspection following observations were made:-

1. Hose Reel Hose is provided but found non-functional and damaged condition.
2. Terrace level fire pump capacity of 220 LPM is provided but found non-functional and damaged condition.
3. Terrace level water tank of capacity 2500 ltrs. is being used for domestic purpose. Fire water tank must be dedicated to firefighting purpose only.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-

1. URMILA RANI , A-15282, A-BLOCK, GALI NO.-17, BURARI, DELHI, 110084
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.