



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026032601860

Dated: 10-06-2026

SHORTCOMING(S)

With reference to your application ID **52026032601860** dated **10-06-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **MALVIYA MODEL SCHOOL** at **STREET NO 5, VISHWAS NAGAR, DELHI 110032** from fire safety point of view in presence of **Smt. Varsha Sharma** on dated **25/05/2026** During the course of inspection following observations were made:-

1. First Aid Hose reels not provided.
2. Terrace pump capacity 220 lpm head 40 meter not provided.
3. Over head tank 2500 liter not provided.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. SARTHAK VATS , 1/4, street no 5 , vishwas nagar, delhi, 110032
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.