



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026032801889

Dated: 01-05-2026

SHORTCOMING(S)

With reference to your application ID **52026032801889** dated **01-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Jagannath International School** at **D-Block, Pushpanjli Enclave, Pitampura, Delhi-110034** from fire safety point of view in presence of **Mr. Vikas Kaushik** on dated **20/04/2026** During the course of inspection following observations were made:-

- 1.Fire Check Doors (FCDs) are not provided.
- 2.Smoke management system in basement at some places found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-

1. Ritesh Gupta, H-2/1, MODEL TOWN, DR. MUKHERJEE NAGAR, NORTH WEST, 110009
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.