



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026033001935

Dated: 21-05-2026

SHORTCOMING(S)

With reference to your application ID **52026033001935** dated **21-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sharon Public School** at **D-264, Gali No. 11, Laxmi Nagar East, Delhi-92**. from fire safety point of view in presence of **Mrs. Sheetal, Principal** on dated **07/05/2026** During the course of inspection following observations were made:-

1. An Additional staircase having width not less than 0.75 m is required.
2. All water based systems like Hose reels & fire pump found non functional.
3. Exit signages found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. YONATHAN WILKINSON SAIT , D-264, GALI NO-11, LAXMI NAGAR, EAST DELHI, 110092
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.