



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026040201996

Dated: 05-05-2026

SHORTCOMING(S)

With reference to your application ID **52026040201996** dated **05-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Rajkiya Partibha Vikas Vidyalaya** at **Plot No. 01. Link Road, Jhandewalan, New Delhi** from fire safety point of view in presence of **Mr. Mohd, Iftekhar Alam, Teacher** on dated **22/04/2026** During the course of inspection following observations were made:-

- 1.Hose reel pipes found damaged and nozzles found missing.
- 2.Fire pump provided on terrace found non-functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. NIKITA , WZ-5 Manohar Park , East Punjabi Bagh, PUNJABI BAGH, DELHI, 110026
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.