



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026040202001

Dated: 29-05-2026

SHORTCOMING(S)

With reference to your application ID **52026040202001** dated **29-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Govt. Girls Sr. Sec. School** at **Khichripur, Delhi** from fire safety point of view in presence of **Mr. Lokesh Kumar, I.T. Assistant** on dated **18/05/2026** During the course of inspection following observations were made:-

1. Nozzle found removed in each hose reel & found non functional.
2. Fire pump found non functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. NEERAJ KUMARI , GGSSS,Khichripur, Khichripur, Block-14, Kalyanpuri, Delhi, 110091
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.