



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026040202003

Dated: 23-05-2026

SHORTCOMING(S)

With reference to your application ID **52026040202003** dated **23-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M/s The Grand Buildtech Limited** at **Kh No. 83,85,90,91,101,102 Chattarpur Mandir Road, Vill Satbari Mehrauli New Delhi** from fire safety point of view in presence of **Sh. Khemchand** on dated **02/05/2026** During the course of inspection following observations were made:-

1. First aid-hose reel are provided but not functional.
2. Automatic sprinkler are provided but not functional.
3. Internal hydrants provided but not functional.
4. Pumping arrangements system provided but not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. VIKAS TYAGI , 16, Bhama Shah Road, The Animals Friend, New Delhi, 110009
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.