



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026042002376

Dated: 01-06-2026

SHORTCOMING(S)

With reference to your application ID **52026042002376** dated **01-06-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Silver Oak Public School** at **A-1, Swaroop Nagar, Delhi** from fire safety point of view in presence of **Sh. Rakesh** on dated **14/05/2026** During the course of inspection following observations were made:-

1. In the basement, 03 staircases of 1.40 m, 1.30 m & 0.85 m width are provided against the requirement of 02 staircases of 1.5 m width each.
 2. Smoke Management System found removed in basement.
 3. Fire extinguishers found inadequate.
 4. First-aid hose reel hose found non-functional.
 5. Automatic Sprinkler System found non-functional.
 6. Internal Hydrant found removed.
 7. Fire pump of 900 LPM capacity found non-functional.
- Exit signages found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

S.K.DUA
Chief Fire Officer

Copy to:-

1. RAKESH SAINI , 1A, 3RD FLOOR, KH.NO.-5/9, SILVER OAK PUBLIC SCHOOL , SWAROOP NAGAR, LIBASPUR, 110042
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.