



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026042402463

Dated: 29-05-2026

## SHORTCOMING(S)

With reference to your application ID **52026042402463** dated **29-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Sarvodaya Kanya Vidyalaya, Jija Bai, at Kondli, Delhi-91** from fire safety point of view in presence of **Mrs. Smiriti, Principal** on dated **19/05/2026** During the course of inspection following observations were made:-

1. An additional staircase having width 1.50 meters is required at G block.
2. All water based system like Hose reels, Fire pump found non functional at G and H block.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

**Dr.S.K.Tomar**  
**Chief Fire Officer**

### Copy to:-

1. RSKV KONDLI JEEJABAI , RAJKIYA SARVODAYA KANYA I, KONDLI, KALYAN PURI, NEW DELHI, 110092
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.