



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026042502486

Dated: 08-09-2026

SHORTCOMING(S)

With reference to your application ID **52026042502486** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **S.S. PUBLIC SCHOOL** at **B-545, SANGAM VIHAR, NEW DELHI**. from fire safety point of view in presence of **Sh. Neeraj** on dated **14/07/2026** During the course of inspection following observations were made:-

1. School is not accessible to fire engine as approach road width is less than 06m.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. neeraj siwas , HOUSE NO. 290/13, DEOLI VILLAGE, NEAR BIHARI PARK, NEW DELHI, 110062
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.