



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026042902590

Dated: 11-05-2026

SHORTCOMING(S)

With reference to your application ID **52026042902590** dated **11-05-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Plot No. C, Community Centre** at **Vivek Vihar, Delhi-110095** from fire safety point of view in presence of **Mr. Arun Sharma** on dated **06/05/2026** During the course of inspection following observations were made:-

1. Internal Road found encroached.
2. Smoke management system in Basement and Upper floors provided but not functional.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. SUNIL KUMAR JAIN , 71 UGF, Sandesh Vihar, , Pitampura, Delhi, 110034
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.