



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026050102642

Dated: 08-06-2026

SHORTCOMING(S)

With reference to your application ID **52026050102642** dated **08-06-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Multi Level Car Parking** at **Terminal -3, IGI Airport, New Delhi-110037** from fire safety point of view in presence of **Mr. Anil Sharma** on dated **16/05/2026** During the course of inspection following observations were made:-

1. PA System is not available in 6th floor office area.
2. Lift Pressurization system found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. NAGENDRA NATH TIWARI , Flat no 505 Tower 4 , Nirala Estate, Hanuman Ma, Greater Noida West, Gautam Budh Nagar, 201306
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.