



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026051502933

Dated: 14-08-2026

SHORTCOMING(S)

With reference to your application ID **52026051502933** dated **14-08-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **K.S Memorial Public School** at **M.B Road, Ghitorni, New Delhi-110030** from fire safety point of view in presence of **Sh Jaganwati Lohia** on dated **04/08/2026** During the course of inspection following observations were made:-

1. First Aid Hose Reels provided but not functional.
2. Main Fire pump 450 LPM is provided but not on auto mode.
3. Exit signage are found removed at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-

1. JAGANWATI LOHIA , FARM NO 45, ROAD NO 02, SILVER OAK FARM GHITORNI, NEW DELHI, 110030
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.