



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026051802991

Dated: 08-09-2026

SHORTCOMING(S)

With reference to your application ID **52026051802991** dated **08-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M.R. Memorial Public School** at **Sultan Pur Road, Karala, Delhi-110081** from fire safety point of view in presence of **Sh. Sumit, Owner** on dated **15/07/2026** During the course of inspection following observations were made:-

- 1.02 nos. staircases are 1.50 m and 1.40 m against the requirements of 1.50 m clear width each and Both staircases are not upto terrace floor.
- 2.Hose-Reel-Hose is not provided.
- 3.Fire pump of 450 LPM is not provided.
- 4.Overhead water storage tank of 10,000 ltrs. capacity is not provided.
- 5.Exit signages are not provided.
6. Standby power supply is not provided

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. Jagbir Singh Mathur , House no. 342 Bazar Panna, Near SBI Bank, karala , New Delhi, 110061
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.