



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026060603451

Dated: 10-08-2026

SHORTCOMING(S)

With reference to your application ID **52026060603451** dated **10-08-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **NBCC Tower 15** at **15 Bhikaji Cama Place, New Delhi** from fire safety point of view in presence of **Sh Heramb Pandey** on dated **27/07/2026** During the course of inspection following observations were made:-

1. First Aid Hose reels provided but not functional.
2. Public Address system provided but not functional.
3. Main Pump capacity of 2400 LPM x 2 is provided but not on auto mode.
4. exit signage is not provided

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-

1. Heramb Pandey , 9D, KALKA JI EXTENSION, Fort View Apartment, NEW DELHI, 110019
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.