



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026061203633

Dated: 22-07-2026

SHORTCOMING(S)

With reference to your application ID **52026061203633** dated **22-07-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Lavish The Party Lawn** at **G.T.K. Road, Palla Bakhtawarpur Road, Delhi 110036** from fire safety point of view in presence of **Sh. Ranjan, employee** on dated **10/07/2026** During the course of inspection following observations were made:-

1. Hose reel provided but not functional.
2. MOEFA provided but not functional.
3. Yard Hydrant provided but not functional.
4. Terrace pump of 900 LPM and 40 M Head provided but not functional.
5. Overhead tank of 7000 Litres capacity is provided against the requirement of 15,000 Litres.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. Amrit Singh Bawa , 2/ 12, First Floor, Ansari Road, Daryaganj, Delhi, 110002
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.