



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026061803767

Dated: 24-07-2026

SHORTCOMING(S)

With reference to your application ID **52026061803767** dated **24-07-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **MAHARAJA AGRASEN VIDYAPEETH, ROHTAK ROAD, MUNDKA, DELHI-110041** at **ROHTAK ROAD, MUNDKA, DELHI-110041** from fire safety point of view in presence of **Mrs. Asha Dabas, Teacher** on dated **07/07/2026** During the course of inspection following observations were made:-

1. Overhead tank of 2000 Litre is provided against the requirement of 10000 Litre.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-

1. SIMPLE KAPOOR , H-5, HARSH APARTMENT, PEERA GARHI, DELHI, 110087
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.