



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026062403943

Dated: 10-09-2026

SHORTCOMING(S)

With reference to your application ID **52026062403943** dated **10-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Deepshikha Building** at **Plot no. 8, Rajendra Place New Delhi-110008** from fire safety point of view in presence of **Bishamber Mandal** on dated **21/08/2026** During the course of inspection following observations were made:-

1. Main staircase found blocked due to renovation work in progress in the stair.
2. Fire check door found removed in the basement.
3. MOEFA is not working at 6th floor.
4. Lift and exit signage found removed at some locations.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. Bishamber Mandal , FLAT NO 7, PREM DHAM APPARTMENT 2, devoli, DELHI, 110080
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.