



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026070204186

Dated: 24-07-2026

SHORTCOMING(S)

With reference to your application ID **52026070204186** dated **24-07-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Community Centre, Plot No. 7, Anushka Tower-2** at **Garg Trade Centre, Sector-11, Rohini, Delhi-110085** from fire safety point of view in presence of **Sh. Parvender Singh, Manager** on dated **08/07/2026** During the course of inspection following observations were made:-

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-

1. SATISH KUMAR GARG , D-26, EAST PUNJABI BAGH, BHAGWANDASS NAGAR, DELHI, 110026
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.