



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026070404216

Dated: 05-08-2026

SHORTCOMING(S)

With reference to your application ID **52026070404216** dated **05-08-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Govt. Boys Senior Secondary School No. 2** at **Roop Nagar, Delhi - 110007** from fire safety point of view in presence of **Mr. Shashi Prakash** on dated **03/08/2026** During the course of inspection following observations were made:-

1. Fire extinguisher's provided but non functional.
2. First aid hose reels provided but non functional.
3. Terrace fire pump provided but not functional and not on auto start mode.
4. Exit signages are not adequately provided.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Sachin Rana, IAS
Pr. Director

Copy to:-

1. SHASHI PRAKASH , KH.NO.818/1/1 LAL DORA PL, GALI NO -1 , BURARI, DELHI, 110084
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.