



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026071404448

Dated: 24-09-2026

SHORTCOMING(S)

With reference to your application ID **52026071404448** dated **24-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M/S Bright Way Public School** at **2nd 60 Feet Road, Molarband Extn., New Delhi-44.** from fire safety point of view in presence of **Sh Vijay** on dated **11/08/2026** During the course of inspection following observations were made:-

1. Main Fire fighting pump capacity of 450 LPM is provided but not on Auto-Mode.
2. Overhead tank capacity of 10,000 ltrs is not provided.
3. Exit Signage are not provided at some places.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. Vijay Lata Sharma , 2892, 69, BLOCK E2, MOLAR BAND, 110044
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.