



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026072004563

Dated: 01-08-2026

SHORTCOMING(S)

With reference to your application ID **52026072004563** dated **01-08-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M.C. Primary Co-ed School** at **Lalita Block, Shastri Nagar, New Delhi-110052** from fire safety point of view in presence of **Ms. Sonia** on dated **24/07/2026** During the course of inspection following observations were made:-

1. First aid hose reel found provided but not functional and nozzle found missing.
2. Terrace level pump and overhead tank could not be checked as terrace found under lock and Key.
3. Exit signages found removed.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. SUMAN , 348 3rd floor D A Block, Sheesh Mahal Park, Shalimar bagh, Delhi, 110088
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.