



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026072904760

Dated: 11-09-2026

SHORTCOMING(S)

With reference to your application ID **52026072904760** dated **11-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **Ansal's Laxmi Deep Building** at **Plot No. 9, District Centre, Laxmi Nagar, Delhi-110092** from fire safety point of view in presence of **Sh. Kuldeep Saharan, DGM** on dated **19/08/2026**

During the course of inspection following observations were made:-

1. Panic bar handle found removed from the Fire Check Door (FCD).
2. Smoke Management system found removed in the basement and upper floors.
3. MOEFA provided but not functional.
4. PA system provided but not functional.
5. Refuge area are encroached at 5th, 6th, 7th and 8th floor.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

Dr.S.K.Tomar
Chief Fire Officer

Copy to:-

1. Ansal Housing Ltd , 2310, SECTOR14, SECTOR14, HISAR, 125001
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.