



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026081305034

Dated: 23-09-2026

SHORTCOMING(S)

With reference to your application ID **52026081305034** dated **23-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **M/s Priya Global** at **B-22, Mayapuri, Industrial Area, Phase-II, New Delhi-64** from fire safety point of view in presence of **Mr. Tarun, Owner** on dated **21/08/2026** During the course of inspection following observations were made:-

1. Smoke management system found removed in basement.
2. Fire Extinguisher found empty at some locations.
3. Hose reel hose and sprinkler system provided but found non functional.
4. Terrace level pump provided but found non functional.
5. Over head tank of capacity 10,000 liters provided against the requirement of 20,000 liters.

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. PRIYA GLOBAL , EA191, TAGORE GARDEN, TAGORE GARDEN, DELHI, 110027
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.