



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001



Application ID. 52026081405050

Dated: 23-09-2026

SHORTCOMING(S)

With reference to your application ID **52026081405050** dated **23-09-2026** on the subject cited above, it is informed that officer concerned of this department inspected the **God Grace Welfare & Education Society** at **Plot No.05, Nikhil Plaza, Service Centre, Sector-03, Rohini, Delhi-110085** from fire safety point of view in presence of **Sh. Rajiv Sharma (Manager)** on dated **30/08/2026** During the course of inspection following observations were made:-

1. Fire check doors found removed at some places.
2. Smoke management systems found removed in basement.
3. Hose reel hose is provided but not functional.
4. Sprinklers systems is provided but not functional.
5. Internal hydrant is provided but not functional.
6. Terrace level fire pump is provided but not functional & not in auto mode.
7. Three temporary rooms constructed on terrace level required needs to be removed.
8. The basement is being used as a banquet hall, whereas as per the drawing submitted by the owner/occupier, it is shown as storage

In view of the above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore, the application is rejected with the directions to apply again after compliance of above mentioned shortcomings under intimation to this office for further course of action.

A.K.Malik
Chief Fire Officer

Copy to:-

1. GOD GRACE WELFARE AND EDU SOCIETY , BLOCK -G, SECTOR 3 ROHINI, NEW DELHI, ROHINI, NEW DELHI, 110085
2. The Concerned Local/Statutory Authority –

This letter is computer generated and does not require signature.