



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Hospital/2026/EZ/ 1924

Dated: 01/09/2026

To

The Medical Superintendent,
D.G.H.S (Nursing Home Cell),
Government of NCT of Delhi,
3rd Floor, Delhi Govt. Dispensary Bldg.
S-1, School Block, Shakarpur,
Delhi-110092

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Aakar Multispeciality Hospital at H. No. 1/A, Khasra No, 167, Village Mandoli, Near MCD School, Delhi-110093

Sir,

This has reference to your letter No. F.24/1293/NED/DGHS/NHC/2026-29/2026-2027 dated 23/06/2026 received in this office through outdoor diary No. 3702 dated 13/07/2026, on the subject above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 17/08/2026 from fire/life safety point of view in the presence of Dr. Pawan Sharma (MS). During course of inspection, the shortcomings observed are as below.

1. Single staircase having width of 1.10 meter found provided against two staircases of 2.0m and 1.50m.
2. Width of corridors at ground floor is less than the required width of 2.4 meter.
3. Hose-reel hose provided but non-functional.
4. The required number of sets of pumps each consisting of one electric and one diesel pump (stand by) of capacity 1620 litre/min and one electric pump of capacity 180 litre/min with requisite head shall be provided.
5. The underground captive water tank of 75,000 liters and overhead water tank of 10,000 liters exclusive for fire-fighting not provided.
6. The fireman's switch, communication in lift car found non-functional and lift signage not provided.

In view of the above shortcomings, application for issuance of fire safety certificate cannot be considered at this stage. You are requested to direct to the applicant to rectify the above-mentioned shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


31/8/26

(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. Dr. Pawan Sharma, Medical Superintendent M/s Aakar Multispeciality Hospital at H. No. 1/A, Khasra No, 167, Village Mandoli, Near MCD School, Delhi-110093