



C-65

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110 001**

No.F6/DFS/MS/EH/2026/NDZ/ 691

Dated: 19/08/2026

**FIRE SAFETY CERTIFICATE**

Certified that the M/s AAM Restro Private Limited located at Plot No.6, Upper Ground Floor, Hargobind Enclave, Karkardooma, Delhi-110092, comprising of Basement, Stilt, Ground plus upper floor but restaurant is running ground floor only owned/occupied by M/s AAM Restro Private Limited was inspected by the officer concerned of this department on 27/07/2026 in the presence of Sh. Aman Gupta, Owner and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy class "Assembly" Group 'D' (Ground floor only) with effect from 19/08/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010. Conditions Mentioned Below.

Issued on 19/08/2026 at New Delhi by.

  
19/8/26

(Dr. S. K. TOMAR)  
CHIEF FIRE OFFICER  
DELHI FIRE OFFICER

To,

- o/c R.
1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
  2. Sh. Aman Gupta, Owner, M/s AAM Restro Private Limited located at Plot No.6, Upper Ground Floor, Hargobind Enclave, Karkardooma, Delhi-110092

MCD ID No. 2026070809632

**Conditions for the validity of Fire Safety Certificate:-**

1. FSC is valid for ground floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : M/s AAM Restro Private Limited  
Plot No.6, Upper Ground Floor, Hargobind Enclave, Karkardooma, Delhi-110092
2. Building is comprised of : Basement, Stilt, Ground plus three upper floors  
but restaurant is running at Ground Floor only  
Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New
4. Details of Previous NOC letter : Nil
5. Fire Safety directive letter No : NBC Part IV
6. Date of Inspection : 27/07/2026
7. Name of the Inspecting officers : Deepak Kumar, ADO (Shd.)
8. Name and designation of Officer  
from the building side : Sh. Aman Gupta, Owner
9. Year of Construction : 2004
10. Applicant's letter No : 2026070809632 dated 08/07/2026

| Sr. No. | Minimum Standards on fire prevention and fire safety U/R33 | NBC Part IV Requirements | Provided at Site     | Remarks MR/NMR |
|---------|------------------------------------------------------------|--------------------------|----------------------|----------------|
| 01      | Access to building                                         |                          |                      |                |
|         | • Road width                                               | 06 m                     | 12 mtr               | MR             |
|         | • Gate width                                               | N/A                      | N/A                  | N/A            |
|         | • Width of internal road                                   | N/A                      | N/A                  | N/A            |
| 02      | Number, Width, Type and Arrangement of Exits               |                          |                      |                |
|         | a. Number of Staircases                                    |                          |                      |                |
|         | • Upper Floor                                              | 02 nos.                  | 02 nos.              | MR             |
|         | • Basement                                                 | 02 nos.                  | 02 nos.              | MR             |
|         | b. Width of Staircases                                     |                          |                      |                |
|         | • Upper Floor                                              | 1.50 mtr                 | 1.50 mtr & 02 mtr    | MR             |
|         | • Basement                                                 | N/A                      | 1.50 mtr & 02 mtr    | N/A            |
|         | c. Protection of exits                                     |                          |                      |                |
|         | • Fire check door                                          | N/A                      | N/A                  | N/A            |
|         | • Pressurization                                           | N/A                      | N/A                  | N/A            |
|         | d. No. of continuous staircases to terrace                 | N/A                      | 01 no.               | N/A            |
|         | e. width of Corridor                                       | N/A                      | N/A                  | N/A            |
|         | f. No. of doors                                            | 02 nos.                  | 02 nos.              | MR             |
|         | g. Door Size                                               | 1.50 mtr                 | 1.50 mtr & 1.50 mtr  | MR             |
| 03      | Compartmentation.                                          |                          |                      |                |
|         | • Fire check door                                          | Required                 | Provided in kitchen  | MR             |
|         | • Sealing of electrical shafts                             | N/A                      | N/A                  | N/A            |
|         | • Fire rating of shaft door                                | N/A                      | N/A                  | N/A            |
|         | • Water curtain                                            | N/A                      | N/A                  | N/A            |
|         | • Fire Dampers                                             | N/A                      | N/A                  | N/A            |
| 04      | Smoke Management System                                    |                          |                      |                |
|         | • Basement                                                 | N/A                      | N/A                  | N/A            |
|         | • Upper floor                                              | Required                 | Mechanical (Exhaust) | MR             |
| 05.     | Fire Extinguishers.                                        |                          |                      |                |
|         | • Total numbers                                            | 04 nos.                  | 06 nos.              | MR             |
|         | • types                                                    | ABC/CO <sub>2</sub>      | ABC/CO <sub>2</sub>  | MR             |
|         | • ISI marking                                              | Required                 | Provided             | MR             |

|    |                                               |             |             |     |
|----|-----------------------------------------------|-------------|-------------|-----|
| 06 | First-aid-Hose Reels.                         |             |             |     |
|    | Total numbers on each floor                   | 01 no.      | 01 no.      | MR  |
|    | • Length of hose reel hose                    | 30 mtr.     | 30 mtr.     | MR  |
|    | • Nozzle diameter                             | 05 mm       | 05 mm       | MR  |
| 07 | Automatic fire detection and alarming system. |             |             |     |
|    | • Type of detectors                           | N/A         | N/A         | N/A |
|    | • Location of main panel                      | N/A         | N/A         | N/A |
|    | • Location of repeater panel                  | N/A         | N/A         | N/A |
|    | • Alternate source of power                   | N/A         | N/A         | N/A |
|    | • Hooter's location                           | N/A         | N/A         | N/A |
| 08 | MOEFA                                         | Required    | Provided    | MR  |
| 09 | Public address System.                        | N/A         | N/A         | N/A |
| 10 | Automatic Sprinkler System.                   |             |             |     |
|    | • Basement                                    | N/A         | N/A         | N/A |
|    | • upper floor                                 | N/A         | N/A         | N/A |
|    | • sprinkler above false ceiling               | N/A         | N/A         | N/A |
| 11 | Internal Hydrants                             |             |             |     |
|    | • size of riser/down-comer                    | 100 mm      | 100 mm      | MR  |
|    | • Number of hydrants per floor                | 01 no.      | 01 no.      | MR  |
|    | • Hose Box                                    | 01 no.      | 01 no.      | MR  |
| 12 | Yard Hydrants.                                |             |             |     |
|    | • Total number of hydrants                    | N/A         | N/A         | N/A |
|    | • Hose Box                                    | N/A         | N/A         | N/A |
| 13 | Pumping Arrangements                          |             |             |     |
|    | • Ground Level                                |             |             |     |
|    | ➤ Discharge of main Pump                      | N/A         | N/A         | N/A |
|    | ➤ Head of Main Pump                           | N/A         | N/A         | N/A |
|    | ➤ Number of main pumps                        | N/A         | N/A         | N/A |
|    | ➤ Jockey pump out put                         | N/A         | N/A         | N/A |
|    | ➤ Jockey pump head                            | N/A         | N/A         | N/A |
|    | ➤ Standby pump out put                        | N/A         | N/A         | N/A |
|    | ➤ Standby pump Head                           | N/A         | N/A         | N/A |
|    | ➤ Auto Starting /Manual stopping              | N/A         | N/A         | N/A |
|    | ➤ Pump House Access                           | N/A         | N/A         | N/A |
|    | • Terrace Level                               |             |             |     |
|    | ➤ Discharge of pump                           | 450 lpm     | 900 lpm     | MR  |
|    | ➤ Head of the Pump                            | 40 m        | 40 m        | MR  |
|    | ➤ Power supply                                | Required    | Provided    | MR  |
|    | ➤ Auto Starting of pump                       | Required    | Provided    | MR  |
| 14 | Captive Water Storage for Fire Fighting.      |             |             |     |
|    | • Underground tank capacity                   | N/A         | N/A         | N/A |
|    | ➤ Draw-off connection                         | N/A         | N/A         | N/A |
|    | ➤ Fire service inlet                          | N/A         | N/A         | N/A |
|    | ➤ Access to tank                              | N/A         | N/A         | N/A |
|    | • Overhead Tank capacity                      | 20,000 ltrs | 20,000 ltrs | MR  |
| 15 | Exit Signage.                                 | Required    | Provided    | MR  |
| 16 | Provision of Lifts                            |             |             |     |
|    | • Pressurization of Lift Shaft                | N/A         | N/A         | N/A |
|    | • Pressurization of Lift lobby                | N/A         | N/A         | N/A |
|    | • Communication in lift car                   | N/A         | N/A         | N/A |
|    | • Firemen's grounding switch                  | N/A         | N/A         | N/A |
|    | • Lift Signage                                | N/A         | N/A         | N/A |

N/24.

|    |                                                                          |     |     |     |
|----|--------------------------------------------------------------------------|-----|-----|-----|
| 17 | Standby power supply                                                     | N/A | N/A | N/A |
| 18 | Refuge Area.                                                             |     |     |     |
|    | • Total area                                                             | N/A | N/A | N/A |
|    | • Location                                                               | N/A | N/A | N/A |
| 19 | Fire Control Room                                                        |     |     |     |
|    | • Detector system panel                                                  | N/A | N/A | N/A |
|    | • Flow switch panel                                                      | N/A | N/A | N/A |
|    | • PA system panel                                                        | N/A | N/A | N/A |
|    | • Battery backup                                                         | N/A | N/A | N/A |
|    | • Building Floor Plans                                                   | N/A | N/A | N/A |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under rule, **It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.**

*Deepak*  
29/07/2026,

Signature of the Inspecting Officer

Name :-Deepak Kumar

Designation :-ADO (Shahdara)

DO (ED)

*Deepak*  
04/08/26

CFO (East Zone)

*KT*  
14/8/26

Principal Director

CFO to issue

*me*  
CFO

CFO (CZ)

*KT*  
14/8/26

ADD SHAH

pl. Sir, F.T. letter is put up for your kind signature

CFO (East Zone)

*Deepak*  
18/08/2026

*KT*  
18/8/26

ms

Deemed approved.