

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

75  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/NDZ/2025/ 588

Dated:-04/12/2025

To,

The Assistant Engineer (Elect.) - IV,  
Office of Assistant Engineer (Electrical) -IV,  
Dr. R.M.L. Hospital, Elect. Division,  
C.P.W.D., New Delhi-110001.

**Sub: Regarding issuance of Fire NOC for ABVIMS Block at Dr. R.M.L. Hospital, New Delhi.**

Sir,

This has reference to your letter No. AE(E)-IV/DRMLHED/2025-26/406 dated 13/10/2025 on the subject cited above. In this connection, it is to inform you that the premises (ABVIMS Block, Dr. R.M.L. Hospital, New Delhi) was visited by the officers concerned of this department on 14/11/2025 in the presence of Sh. D. S. Meen, AE (Elect.) & Smt. Harshita, JR (Civil) and following shortcomings were observed.

1. All around 06 mtr. wide motorable road with 09 mtr. turning radius for fire tender movement was not provided.
2. Pressurization system for lift shafts, lift lobbies and staircases was not provided.
3. Hoses were not provided in hose box at some places.
4. Hose reel provided but found non-functional and nozzle found missing at some places.
5. Yard hydrant found damaged at some places.
6. Smoke management system provided but found non-functional.
7. Exit signages, floor signages & lift signages were not provided at some places.
8. Sprinklers were not provided above the false ceiling.
9. Overhead water storage tank found was not connected with firefighting system.
10. Detectors were not provided at some places.
11. Fire check doors were not provided in lift lobby and staircase etc. at some places.
12. Compartmentation was not provided in basement.

Auditorium at ground floor found under renovation, hence could not be checked.

In view of the above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(Dr. S. K. Tomar)

Dy. Chief Fire Officer  
Delhi Fire Service

OK BR