



No F 6/DFS/MS/GH/2025/NDZ/ 551

Dated: 28/11/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Adam Guest House located at 3843, Machhali Walan, Khirki Tafazzul Hussain, Jama Masjid, Delhi-110006 comprised of Ground + 03 Upper floors, Ground floor (Reception + Office + 09 Beds dormitory), 1st floor (03 Guest rooms + 01 Store), 2nd floor (05 Guest Rooms) & 3rd floor (05 Guest Rooms), total 13 guest rooms & 09 beds dormitory was issued FSC by this department vide letter No F6/DFS/MS/GH/NDZ/2022/522 dated 02.12.2022. The premise was re-inspected by the officer concerned of this department on 15.11.2025 in the presence of Mohd. Nasir and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy "Class A, Residential (Guest House for total 13 Guest Rooms and 09 Bed Dormitory from Ground floor to 3rd floor only)" with effect from ..28.11.2025.. for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on28.11.2025 at New Delhi, by


28/11/25

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi- to ensure the occupancy as detailed above.
2. M/s. Adam Guest House located at 3843, Machhali Walan, Khirki Tafazzul Hussain, Jama Masjid, Delhi-110006.
3. MCD Portal, ID No. 2025110514616.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (<https://www.mcdonline.gov.in>) along with a copy of this Certificate, six months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed/ unlocked for unhindered evacuation in case of an emergency.

N-23

INSPECTION REPORT

1. Name & address of the building : M/s Adam Guest House located at 3843, Machhali Walan Khirki Tafazzul Hussain, Jama Masjid, Delhi- 110006.
2. Type of Occupancy : Residential Building (Sub Division A-1).
3. Building Comprised of : Ground plus Three upper floors
Ground Floor- Reception + Office + 09 Bed Dormitory
First Floor- 03 Guest Rooms + 1 Store room
Second Floor- 05 Guest Rooms &
Third Floor- 05 Guest Rooms
4. Type of Case : Renewal (old case)
5. Details of Previous NOC : F6/DFS/MS/GH/NDZ/2022/522 Dated 02/12/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 15/11/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (Jawala Puri)
9. Name and designation of officers
 From the building side : Mohd. Nasir
10. Year of Construction : 1978 as per MCD portal
11. Applicant's letter No. : MCD Portal ID No. 2025110514616 dated 05/11/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per inspection report dated 28/11/2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	NA	Inaccessible to fire engine	Cover under special area
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	01 No.	01 No.	MR
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	0.80 m	0.87 m to 1.10 m	MR
	Basements	NA	NA	NA
	Protection of exits	NA	NA	NA
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	01 No.	01 No.	MR
	Width of Corridor	NA	NA	NA
	Door Size	0.80 m	1 m	MR
3.	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA

N-27

		Required	Provided	MR
	Upper floor			
5.	Fire Extinguishers			
	Total numbers	08 Nos.	08 Nos.	MR
	Types	ABC/Co2 Type	ABC & Co2	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01	01	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	6.5 mm	6.5 mm	MR
7.	Automatic fire detection and alarming system			
	Type of detectors	CO	CO	MR
	Location of Main Panel	Required	Provided	MR
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	Required	Provided	MR
	Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Entire restaurant	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	450 lpm	MR
	Head of the pump	30 m	30 m	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			

k


24

M/s Adam Guest House, 3843, Machhali Walan, Khirki Tafazzul Hussain, Jama Masjid, Delhi.

	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	25,00 ltrs	25,00 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is **recommended to renew the Fire Safety Certificate** issued vide letter no. F6DFS/MS/GH/NDZ/2022/522 dated 02/12/2022 under Rule 37 of the Delhi Fire Service Rules 2010.


 Signature of Inspecting Officer
 Name : Rajeev Kumar Sinha
 Designation : ADO/Jawala Puri


 Dy. CFS (NDZ)
 20/11/25

Dy. CFS (NDZ)


 20/11/25

Principal Director

Dy. CFS to Sasm.

Dy. CFS (NDZ)


 21/11/25

ADO (JWP)

CO2