

c-66

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE


No. F.6/DFS/MS/School/2025/SZ / 01 **NEW DELHI-110 001.**

Dated: 01 | 01 | 2026

FIRE SAFETY CERTIFICATE

Certified that the Adarsh World School located at Sector- 12, Phase- 1, Dwarka, New Delhi- 110075, comprised of basement (permanently closed), ground floor plus three upper floors, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2022/837 dated 02.08.2022. The school building was re- inspected by the officer concerned of this department on dated 22.12.2025 in the presence of Ms. Savita Sharma (Principal), and found that the school building have complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" w.e.f. 01 | 01 | 2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 01 | 01 | 2026 at New Delhi by.


(A.K. Malik)
Dy. Chief Fire Officer
South Zone

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, Adarsh World School located at Sector- 12, Phase- 1, Dwarka, New Delhi- 75.
3. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

: - for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Presently basement is permanently closed.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/28

INSPECTION REPORT

1. Name & address of the building	:	Adarsh World School at Sec. 12, Dwarka, Ph. 1, New Delhi- 75.
2. Building comprised of	:	Basement (permanently closed), ground plus three upper floors.
3. Type of Occupancy	:	Educational
4. Type of Case	:	Renewal
5. Details of Previous NOC	:	F.6/DFS/MS/School/SZ/2022/837 dated 02.08.2022
6. Fire Safety directives letter No	:	N/A
7. Date of inspection	:	22.12.2025
8. Name of Inspecting Officer	:	A.D.O. R.K. Yadav (DWK)
9. Name and designation of officers	:	
From the building side	:	Ms. Savita Sharma, Principal
10. Year of Construction	:	2005 & 2015
11. Applicant's letter No.	:	AWS/DWK/2025/0307 dated 17.11.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6.0 m 4.5 m N/A	Provided Provided N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 Nos.	02 Nos.	MR
	• Basements	N/A	N/A	Closed
	b. Width of staircases			
	• Upper Floor	1.5 m each	1.5 m each	MR
	• Basements	N/A	N/A	Closed
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.50 m	2.30 m	N/A
	f. Door Size	1.0 m	1.0 m (including door frame)	MR, old case
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	• Total numbers	16 no's	Provided	MR
	• Types	ABC/CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 Nos	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		02	Provided	MR
		Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 ltrs	13,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
		No Lift		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

N/30

	Standby power supply	Required	Provided	MR
Refuge Area.				
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	ABC, Fire extinguisher provided near elect. penal	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings was issued by this department vide letter No. F.6/DFS/MS/School/2025/SZ/796 dated 04.11.2025.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/SZ/2022/837 dated 02.08.2022, **is recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

R.K. Yadav
21/12/2025

Signature of the Inspecting Officer
Name- R.K. Yadav
Designation- A.D.O (SRD)

DO (SW)

[Signature]
23/12/25
Delhi Fire Service
Govt. of Delhi

[Signature]
24/12/25
A.K. MALIK

[Signature]
Principal

[Signature]
By. CFO (SRD)

[Signature]
28/12/25
A.K. MALIK
By. SW)

26/12

By. CFO to Issue.
[Signature]
24/12/25