

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001**

No. F.6/DFS/MS/EH/NDZ/2026/180

Dated: 28/02/2026

To,

Sh. Satish Kumar  
74-A, B-Block, Dilshad Garden,  
Delhi-110095

**Subject: - Regarding renewal of Fire Safety Certificate in r/o Aggarwal Bikaner Sweet at A-1/1, Bhajanpura, Near Khajoori Chowk, Delhi-110053**

Sir,

This has reference to MCD online application ID No. **2026012800961** dated 28/01/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 19/02/2026 in presence of Sh. Sanjeev Kumar. The building is comprised of Basements, Ground plus two upper floors but restaurant is running on ground floor only. The following shortcomings were observed during the time of inspection.

1. First-Aid hose reel found removed.
2. MOEFA provided but not functional.
3. Down comer provided but not functional and hose box is empty.
4. Terrace pump 450 lpm head 40 meters provided but not functional.
5. An over head tank capacity 5,000 liters provided against the requirement of capacity 20,000 liters
6. Exit Signage not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
25/2/26

(Dr. S. K. TOMAR)  
DY. CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above  
MCD ID No. **2026012800961**