



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

c/20

No.F.6/DFS/MS/WZ/Education/2025/ 39

Dated: 29/04/25

To,
Executive Engineer (Bldg.), MCD,
Civic Centre Building, Minto Road,
New Delhi.

Sub: - Regarding issue of "FSC" from fire safety point of view in r/o Ambition Educare Pvt. Ltd. (Coaching Institute) located at No. 106, 107 & 108, 1st floor D-1, Virat Bhawan Commercial Complex, Mukharjee Nagar, North Delhi- 110009.

Sir,

Please refer to your online Request ID 70000133 dated 08.04.2025, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the premises on dated 23.04.2025, to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Miss. Arushi Chaudhary (Academic Head) was present and it was observed that the said coaching institute is running at 1st floor in Virat Bhawan Commercial Complex Building which comprised of basement, ground, mezzanine floor, first, second & third floor, the building having FSC by this department vide letter No. F.6/DFS/MS/2023/BB/CC/25 dated 14.09.2023, and have following shortcomings: -

1. Width of staircases found 1.33 m & 0.90 m to 1.70 m against the required two staircases of width 1.50 m each.
2. Electrical Shafts found not properly sealed.
3. Relocate electric meter boards from corridor to some other safe place.

In view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Gang)
Director
Delhi Fire Service

Copy for information: -

1. Owner/ occupier, M/s Ambition Educare Pvt. Ltd. (Coaching Institute) located at No. 106, 107 & 108, 1st floor D-1, Virat Bhawan Commercial Complex, Mukharjee Nagar, North Delhi- 110009.