

c/137



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6/DFS/MS/GH/2025/NDZ/ 211

Dated: 17/04/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Amrit Guest House** located at **855, S.P.M. Marg, Delhi-110006** comprised of **Ground Floor ( Commercial Use), 1<sup>st</sup> floor (14 Guest Rooms + Reception + Office), 2<sup>nd</sup> floor (12 Guest Rooms + 01 Staff Room) & 3<sup>rd</sup> Floor (18 Guest Rooms)** was issued FSC by this department vide letter No F6/DFS/MS/GH/NDZ/2022/157 dated 21.03.2022. The premise was re-inspected by the officer concerned of this department on 05.04.2025 in the presence of **Sh. Pawan Kumar** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premise is fit for occupancy "**Class A, Residential (Guest House for total 44 Guest Rooms from First floor to 3<sup>rd</sup> floor only)**" with effect from ...**17/04/2025**.... And valid up to 31.03.2028 in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...**17/04/2025**... at New Delhi, by

  
(Anil Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Commissioner, MCD, Civic Centre, New Delhi- to ensure the occupancy as detailed above.
2. M/s Amrit Guest House located at 855, S.P.M. Marg, Delhi-110006.
3. MCD Portal, ID No. 2025032004127.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (<https://www.mcdonline.nic.in>) along with a copy of this Certificate, six months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. This FSC is only for total 44 guest rooms from First floor to 3<sup>rd</sup> floor only.

N-45  
**INSPECTION REPORT**

1. Name & address of the building : Amrit Guest House located at 855, S.P.M. Marg, Delhi- 110006.
2. Type of Occupancy : Residential (A-1) (Total 44 Guest Rooms)
3. Building Comprised of : Ground Floor (Shop with Parchatti), 1<sup>st</sup> floor (14 Guest Rooms+ Reception+ Office, 2<sup>nd</sup> floor (12 Guest Rooms + 01 Staff Room) & 3<sup>rd</sup> floor (18 Guest Rooms)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/GH/NDZ/2022/157 Dated 21/03/2022
6. Fire Safety directives letter No : Nil
7. Date of inspection : 05/04/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
10. From the building side : Sh. Pawan Kumar
11. Year of Construction : 1947 as per MCD Portal
12. Applicant's letter No. : MCD Application ID No. 2025032004127 dated 20/03/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR	Old case
1.	<b>Access to building</b>				
	Road width	6 m	Provided	MR	
	Gate width	NA	NA	NA	
	Width of internal road	NA	NA	NA	
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>				
	Number of staircases				
	Upper Floors	01	02	MR	
	Basements	NA	NA	NA	
	Width of staircases				
	Upper Floor	0.80 m	Gr. to Terrace- 0.82 m to 1.10 m, 1 <sup>st</sup> to 3 <sup>rd</sup> floor- 0.94 m	MR	
	Basements	NA	NA	NA	
	Protection of exits				
	Fire check door	Required	Provided	MR	
	Pressurization	NA	NA	NA	
	No. of continuous staircases to terrace	01	01	MR	
	Width of Corridor	NA	NA	NA	
	Door Size	0.91 m	0.91 m	MR	
3.	<b>Compartmentation</b>				
	Fire check door	NA	NA	NA	
	Sealing of electrical shafts	NA	NA	NA	
	Fire Rating of shaft door	NA	NA	NA	
	Water Curtain	NA	NA	NA	
	Fire Dampers	NA	NA	NA	
4.	<b>Smoke Management System</b>				
	Basements	NA	NA	NA	
	Upper floors	Required	Provided (Natural open courtyard)	MR	
5.	<b>Fire Extinguishers</b>				
	Total numbers	10 Nos.	Provided	MR	
	Types	ABC/Co2 Type	Provided	MR	
	IS marking	Required	Provided	MR	
6.	<b>First-Aid Hose Reels</b>				
	Total numbers on each floor	01	Provided	MR	
	Length of hose reel hose	30 m	Provided	MR	
	Nozzle diameter	5 mm	Provided	MR	
7.	<b>Automatic fire detection and alarming system</b>				

		N-46		
	Type of detectors	CO	Provided	MR
	Location of Main Panel	G.F.	Provided	MR
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	Required	Provided	MR
	Hooters' Location	Required	Strategic locations	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	225 lpm	Provided	MR
	Head of the pump	30 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	Required	Provided	MR
	Overhead Tank capacity	2500 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA

	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans	NA	NA	NA
20. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to renew the fire safety certificate issued vide letter no. F6/DFS/MS/GH/NDZ/2022/157 dated 21/03/2022 under rule 37 of the Delhi Fire Service Rules, 2010. Accordingly DFA is placed on file, please.

*(Signature)*  
 ADO(B.W.)  
 9/4/25

Signature of Inspecting Officer  
 Name : Rajeev Kumar Sinha  
 Designation : ADO/B.W.

Do (K.D)

Rel  
 9/4/25

Dy. C.F.O. (MS)

ADP  
 11/04/25

C.F.O.  
 15/4/2025

Director  
 15/4/25

Dr. FT letter in reply to goi plus

*(Signature)*  
 ADO(B.W.)  
 16/4/25

Director (MS)

*(Signature)*

U/Board  
 12/4/25