

C/12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2026/SZ/36

Dated: 14/01/2026

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Apni Rasoi (A unit of DA Apni Rasoi Dine In LLP) at Prop. No. 452 & 453, Kh. No. 1/5 & 21/3. G.F. Station, Vill- Kakrola, Kakrola Housing Complex, New Delhi- 110078, running at ground floor only in a building comprised of ground plus three upper floors, owned/occupied by M/s. DA Apni Rasoi Dine In LLP, have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010, and verified by the officer concerned of this department on dated 10.01.2026 in the presence of Sh. Shyam (Manager), and found that the building is fit for occupancy Class "D" "Assembly Building" (for restaurant running at ground floor only) w.e.f. 14/01/2026 with a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 14/01/2026 at New Delhi.



(A.K. Malik)

Dy. Chief Fire Officer  
South Zone

Copy to: -

1. The Commissioner, MCD, Delhi: with a request to ensure the occupancy as detailed above and deviation, if any.
2. Online application Id 2025121515739 dated 16.12.2025.

**Conditions for the validity of fire safety certificate: -**

1. The FSC issued for restaurant running at ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/4

## INSPECTION REPORT

1. Name & address of the building : M/s Apni Rasoi (A Unit of DA Apni Rasoi Dine In LLP) at Prop. No. 452 & 453, Kh. No. 1/5 & 21/3, GF, Vill. Kakrola, Kakrola Housing Complex, Delhi- 78
2. Building is comprised of : Ground plus three upper floors.
3. Type of Occupancy : Group D (Assembly) **Restaurant running at Ground floor only**
4. Type of Case : New Case
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : Nil
7. Date of inspection : 10.01.2026
8. Name of Inspecting Officers : A.D.O. R.K.Yadav (JKP)
9. Name and designation of officers  
From the building side : Sh. Shyam (Manager)
10. Year of Construction : 2024
11. Applicant's letter No. : MHA Portal ID 2025121515739 dated 16.12.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 m N/A N/A	Provided N/A N/A	M/R N/A N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<b>Restaurant at Ground floor only</b>		
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 m each (02 nos.)	1.70 m & 1.50 m	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A Required	N/A Provided	N/A MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers in restaurant</li> <li>• Types</li> <li>• IS marking</li> </ul>	<sup>02 nos</sup> <del>05</del> no.'s ABC/CO <sub>2</sub> ISI marked	Provided ABC- 03 & Co2- 03 Provided	M/R M/R M/R
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers at each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	1 Nos. 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R



N/G

17.	Standby power supply	Required	Provided	M/R
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued by this department vide letter No. F.6/DFS/MS/NDZ/2025/336 dated 12.08.2025 have been rectified.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules **it is recommended to grant Fire Safety Certificate** under Rule 35 of the Delhi Fire Service Rule 2010. *Last Date is 14-01-2026.*

*R.K. Yadav*  
 Signature of the Inspecting Officer  
 Name: - R.K. Yadav  
 Designation: - ADO (DWK)

*DO (SW)*

*[Signature]*

12/1/26

RAJINDER ATWAL

*Dy. Ch. (SZ)*

*[Signature]*  
 12/1/26  
 A.K. MALIK

*Principal Director*

*My. of to Secy.*

*My. of (SZ)*

*[Signature]*  
 13/01/26

*[Signature]*  
 14/1/26  
 A.K. MALIK

*DO (SW)*

*[Signature]*  
 14/1  
 ADO (DWK)

PTC