



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

CSJ

No. F6/DFS/MS/college/SZ/2026/ 873

Dated: / 14/09/2026

To,

The Commissioner MCD,
Civic Centre, Minto Road,
New Delhi- 110002.

Sub: Regarding issuance of FSC from fire safety point of view in r/o. M/s Arya Bhatta College, Plot No. -5, Benito Juarez Marg, South Campus, Anand Niketan, New Delhi- 110021.


Sir,

Please refer to your letter No. 23(03)/AE(E)/Sub-Division-1/DED-51/2026-27/61 dated 08/06/2026, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 17/08/2026 in the presence of Sh. Mukesh Meena (AE) & Sh. Abishek Deshwal (JE) to see the functioning of fire safety arrangements/equipment's provided in the building. During inspection, the following shortcomings were observed.

1. Overhead water storage tank capacity of 20,000ltrs (Admin block) and 5000ltrs (academic block) are provided but not connected with fire pump.
2. Pressurization of lift lobby & lift shaft is not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is cannot considered at this stage & rejected.

Yours faithfully,


14/9/26
(A.K. Malik)
Chief Fire Officer

012 841

Copy To: -

1. The authorized signatory, M/s Arya Bhatta College, Plot No. -5, Benito Juarez Marg, South Campus, Anand Niketan, New Delhi- 110021.