

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001



No. F.6/DFS/MS/WZ/EH/2026/165

Dated: 23/02/2026

To,

Mr. Rohan Ratan Khare,
House No.D-77, Shubham Enclave, Paschim Vihar,
Delhi-110063.

Sub: Renewal of FSC in r/o M/s Asur (A unit of Mashtun Hospitality LLP) located at 6A, GF, FF, SF and TF, Shivaji Marg, Moti Nagar, Delhi-110015.

Sir,

This is refer to online application no. 2026012000683 dated 31.01.2026, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 09.02.2026, in presence of Mr. B.N Pandey to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. No restaurant occupancy found running 2nd and 3rd floor.
2. Smoke detector is provided but not functional.
3. Public Address system provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

Yours faithfully



(S. K. Dua)

Dy. Chief Fire Officer (WZ)
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2026012000683 dated 31.01.2026.

DL
AWP