

C-7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2025/SZ/ 477

Dated: 11/12/2025

To,

The Owner/Occupier,
M/s Bay Leaf Cafe,
Plot No. 1B/1, Kh. No. 73/5/2, GF,
Behind D-2, Heritage School, Vasant Kunj, New Delhi- 70.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s. Bay Leaf Caf at Plot No. 1B/1, Kh. No. 73/5/2, GF, Behind D-2, Heritage School, Vasant Kunj, New Delhi- 110070.


Sir,

This has a reference to MCD online application ID No. 2025111014705 dated 11.11.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises/building on dated 28.11.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Sourabh (Manager) was present and it was observed that the aforesaid eating running at ground floor only, and following shortcomings were observed: -

1. One door of 1.20 meter found provided against requirement of two doors of 1.50 m each.
2. First aid hose reels found not provided.
3. MOEFA found not provided.
4. Fire pumps capacity of 450 LPM found not provided.
5. Terrace level water storage tank capacity of 20,000 ltrs. found not provided.
6. Exit Sign's found not provided.

Keeping in view of the above, issuance of fire safety certificate can-not be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department, and running eating house in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


4/12/25
(A.K. Malik)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Joint C.P. (Lic.), 1st floor, P.S. Defence Colony, New Delhi- 110024.
2. Online application ID No. 2025111014705 dated 11.11.2025.