



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C 75  
75  
आज़ादी  
अमृत महोत्सव

No. F6/DFS/MS/EH/WZ/2025/ 44

Dated:- 03/02/2025

FIRE SAFETY CERTIFICATE

Certified that the Berco' Restaurant, Located at R-2, Janak Place, District Centre, Janak Puri, New Delhi-110058 is running at ground floor of the Janak Place, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/EH/2022/SZ/13 dated 24/01/2022. The said premise was re-inspected by the officer concerned of this department on 23/01/2025 in the presence of Sh. Rajan (Assistant Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" Group D (Ground Floor only) with effect from 03/02/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on at New Delhi by.

03/02/2025

(Amr Singh)  
Director

Tel. No. 011-23414000

Copy to: -

1. The Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi:- in r/o computer id no. 2025011100412 dated 11/01/2025
2. The Authorized Signatory, Berco's Restaurant, R-2, Janak Place, District Centre, Janak Puri, New Delhi-110058.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : **M/s. Berco's Restaurant, located at R-2, Ground Floor, Janak Place, District Centre, Janak Puri, New Delhi-58**
2. Type of Occupancy : **Assembly, (Restaurant running at ground floor)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/DFS/MS/EH/2022/SZ/13 dated 24/01/2022**
5. Fire Safety directives letter No : **Nil**
6. Date of inspection : **25/01/2025**
7. Name of the Inspecting Officers : **Aman Kumar Lathar, ADO (JWP)**
8. Name and designation of officers from the building side : **Sh. Rajan (Assistant Manager)**
9. Year of Construction : **2002**
10. Applicant's Online ID- : **2025011100412 dated 11/01/2025**

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per earlier FSC dated 24/01/2022	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Directly accessible from internal road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	(restaurant at GF only)
	• Basements	N/A	N/A	(restaurant at GF only)
	b. Width of staircases	-----	-----	-----
	• Upper Floors	N/A	N/A	(restaurant at GF only)
	• Basements	N/A	N/A	(restaurant at GF only)
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	(restaurant at GF only)
	• Pressurization	N/A	N/A	(restaurant at GF only)
	e. No. of continuous staircases to terrace	N/A	N/A	(restaurant at GF only)
	g. Width of Corridor	1.5 m	Provided	MR
	h. Door Size	Two Exit	Provided	MR being old case
3	<b>Compartmentation.</b>			(restaurant at GF only)
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	NA	N/A	N/A
	• Upper floors	Required	Provided in Kitchen	MR

*(Handwritten signature)*

5	<b>Fire Extinguishers</b>			
	• Total numbers	07 Nos.	Provided	MR
	• Types	ABC, CO <sub>2</sub> type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Ground Floor	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements</b>			
	• Ground Level		----	-----
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	N/A
	• Terrace level		-----	-----
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	NA	N/A

	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5,000 ltrs.	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note : Restaurant is having separate own pumping arrangements and overhead water storage tank for hose reel system, internal hydrant system & automatic sprinkler system.

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2022/SZ/13 dated 24/01/2022 is recommended under Rule 37 of the Delhi Fire Service Rules, 2010 under DFS Act 2007.

Accordingly DFA is put up for approval please.

20 (C/D)

28/1/25

Director  
29/01/2025

Aman Kumar Lathar  
ADO (JWP)

P.F.O. (R.V.F.T)