

C-188

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/Hospital/WZ/2025/221

Dated: 13/05/2025

To,

The Assistant Engineer (E), PWD,
HMESD,-1,(North),SGM Hospital,
S-Block, Mangolpuri,Delhi-110083.

Sub : Regarding renewal of NOC/FSC from fire safety point of view in R/o. Bhagwan Mahavir Hospital, Located at Pitampura, New Delhi.

Sir,

Please refer to your letter no. S.23 (1)/AE (E)-1/PWD/SGMH/2024-25232 dated 18/03/2025, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 02/05/2025 in the presence of Sh. Tatsat Mishra (AE/E) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above hospital building is comprised of Basement, ground and four upper floors. Fire safety arrangements such as Fire Extinguishers, first-aid hose reel, automatic fire detection and alarming system, MOEFA, internal hydrant etc provided. However the following shortcomings were observed.

1. Pressurization of lift lobbies are found removed.
2. Fresh Air Fan & Ducts are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

(Anil Garg)
Director

Copy to: -

1. The Medical Superintendent, Bhagwan Mahavir Hospital, Located at Pitampura, New Delhi.
2. The Assistant Engineer (E), PWD, HMESD,-1,(North),SGM Hospital, S-Block, The Executive Engineer (Electrical), HMED (North), PWD, Dr. BSA Hospital, Rohini, Delhi.