

C-6



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No.F.6/DFS/MS/NDZ/EH/2025/162

Dated: 17/04/2025

To,  
The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor Police Station Defence Colony,  
New Delhi

**Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Big Bangs Cafe located at G-1 to G-5, Ground floor, Pankaj Plaza, Plot No.07, LSC, New Rajdhani Enclave Delhi-110092.**

Sir,

This has reference to MCD application ID No. 2025031103290 dated 19/03/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of Mr. Pradeep Kumar Chhajer, Manger on dated 15/04/2025. The building comprised of ground plus two upper floors but Eating house is running ground floor only. The following shortcoming was observed during the time of inspection.

1. Two exit doors of width 1.50 meters are required instead of existing doors having width of 1.40 meters each.
2. Fire check door not provided in the kitchen.
3. First aid hose reels not provided.
4. MOEFA not provided.
5. Terrace pump capacity 450 lpm head 40 meters not provided.
6. An over head tank capacity 20,000 liters not provided.
7. Exit signage not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit..

Yours faithfully

  
**(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE**