



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

C-66

No. F.6/DFS/MS/WZ/EH/2025/ 08

Dated: 05/01/2026

To,  
Mr. Manoj Kumar Pant,  
House No.A-25,  
Gali No.21, Dayalpur Extension,  
Delhi-110094.

**Sub:** Renewal of FSC in r/o M/s Big Boyz Lounge (A unit of Moon Peak Hospitality Pvt. Ltd.) located at Property No.A-6, 3<sup>rd</sup> floor, Rajouri Garden, Delhi-110027.

Sir,

This is refer to online application no. 2025121515721 dated 16.12.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 26.10.2025, in presence of Mr. Rishi (Manager) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. The MS alternate staircase found removed at ground floor.
2. The width of alternate exit door found reduced from 1.50 mtr to 1.1mtr.
3. First Aid hose reel is provided but not functional.
4. MOEFA is provided but not functional.
5. Smoke & Heat detector are provided but not functional.
6. Standby fire pump captive of 2280lpm are provided but not functional.
7. 25,000 ltrs Over Head water captive tank provided against the required capacity of 1,00,000 ltrs & found empty.
8. Standby power supply found removed.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

Yours faithfully

05/01/26  
(S. K. Dua)

Dy. Chief Fire Officer (WZ)  
Delhi Fire Service

Copy To:-

1. MCD Portal Id- 2025121515721 dated 16.12.2025.