

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/EH/2025/NDZ/ 409

Dated : 11/12/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Bikanerwala Foods Pvt. Ltd. Located at Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi** in a building comprised of 2 Basements, Ground + 03 Upper floors **but restaurant running at first floor (only)**, was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2022/NDZ/334 dated 28/11/2022. Now, The premises was re-inspected by the officer concerned of this department on 30/11/2025 in the presence of Sh. Ritesh Mishra, Unit Manager and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules, 2010 and that the premises is fit for **Assembly Occupancy – for Restaurant running at First floor only** with effect from **11 / 12/2025** for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010, printed below.

Issued ..... 11/12/2025 ..... at New Delhi by.

  
 (Dr. S. K. Tomar)  
 Dy. Chief Fire Officer  
 Delhi Fire Service

Copy to: -

1. The Medical Health Officer, NDMC, Palika Kendra, New Delhi.
2. The Commissioner, MCD, Civic Centre, New Delhi (MCD Online ID. 2025112014993 dated 25/11/2025)
3. The Manager, Bikanerwala Foods Pvt. Ltd. Located at Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is only for restaurant at first floor only.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

N/23

## INSPECTION REPORT

1.	Name & address of the building	M/s Bikanerwala Foods Pvt. Ltd. Located at Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi.		
2.	Type of occupancy	Assembly Building Group-D 2B + Gr. + 03 Upper Floors <b>Restaurant running at 1<sup>st</sup> floor only</b>		
3.	Type of case	<b>Renewal</b>		
4.	Details of previous FSC No.	No.F6/DFS/MS/EH/2022/NDZ/334 Dated 28/11/2022		
5.	Fire safety directives No.-	N/A		
6.	Date of inspection: -	30/11/2025		
7.	Name of the inspecting officer: -	Sh. Kaushal Kishore, ADO(SJ)		
8.	Name & designation of officer From the building side: -	Sh. Ritesh Mishra, Unit Manager		
9.	Year of construction: -	Old		
10.	Applicant's letter No: -	Online application ID - 2025112014993 dated 25/11/2025		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NM/R
1.	<b>Access to Building</b>			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	1.5 mtr.	1.5 mtr	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.5 mtr.	1.5 mtr.	MR
3.	<b>Compartmentation</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dumpers	N/A	N/A	N/A
4.	<b>Smoke Management System</b>			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	06 nos.	06 nos.	MR
	• Types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	Required	Provided	MR
6.	<b>First-Aid Hose Reel</b>			
	• Total number of each floor	01 nos.	02 nos.	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7.	<b>Automatic Fire Detection &amp; Alarming System.</b>			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	Required	Provided	MR

	• Location of repeater panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's Location	Required	Provided	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per floor	01 nos.	02 nos.	MR
	• Hose box per floor	01 nos.	02 nos.	MR
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	N/A	02 nos.	N/A
	• Hose box	N/A	02 nos.	N/A
13.	<b>Pumping Arrangement</b>			
	Ground level			
	• Discharge of main pump	2280 LPM	2280 LPM	MR
	• Head of main pump	70 mtr.	70 mtr.	MR
	• Number of main pumps	01 nos.	01 nos.	MR
	• Jockey pump out put	180 LPM	180 LPM	MR
	• Jockey pump head	70 mtr.	70 mtr.	MR
	• Stand by pump output	2280 LPM	2280 LPM	MR
	• Stand by pump head	70 mtr.	70 mtr.	MR
	• Auto starting/Manual stopping	Required	Required	MR
	Terrace level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for Fire Fighting</b>			
	• Underground tank capacity	1,00,000 Ltr	1,00,000 Ltr	MR
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltr	10,000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR

N/25

M/s Bikanerwala Foods Pvt. Ltd. Located at Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi.

	• Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

\*PNF – Provided but Non-Functional, \*MR – Meeting Requirement, \*NMR – Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. No.F6/DFS/MS/EH/2022/NDZ/334 Dated 28/11/2022. The last date for deemed approval is 24/12/2025.

Accordingly, reply letter is prepared and put up for kind perusal and approval please.

Signature of the Inspecting Officer

Name: - Kaushal Kishore  
Designation: - ADO (SJ)

~~DO/CD~~ 02/12/25

~~Dy-CFO (PMA) NDZ~~

31/12/25

~~Principal Director~~

~~My. CFO to Secy.~~

~~My. CFO (NDZ)~~

05/12/25

8/12/25

~~ADD(SJ)~~

08/12/25

FT letter is prepared and put up signature pl.

loaded fsc

~~DUFO/NDZ~~

01/12/25  
ADD/ST