

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/Banq./2025/NDZ/ 610

Dated: 15/12/2025

To,

Sh. Gaurav Kapoor,
M/s Bliss and Blessing Banquet,
A Unit of GRT Fusion Private Limited,
Ground Floor, Jhilmil Metro Station Complex,
Delhi- 110095.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Bliss and Blessing Banquet (A Unit of GRT Fusion Private Limited) located at Ground Floor, Jhilmil Metro Station Complex, Delhi- 110095.

Sir,

This has reference to your online application received through MCD portal vide ID- 2025111714926 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 01/12/2025 in presence of Sh. Sanjay Pandey. Following shortcomings were observed at the time of inspection.

1. Fire check door found broken.
2. First aid hose reel found provided but not functional.
3. Detectors found provided but not functional at some places.
4. Exit signage's found removed.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Dr. S.K. Tomar)

Dy. Chief Fire Officer

Copy to:-

1. MCD Portal ID No. 2025111714926.