



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7-7
75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/ECN/2026/803

Dated: 25/08/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Blue Tokai Coffee Roasters (A Unit of Muhavra Enterprises Pvt. Ltd.), Unit No. M17, Ground Floor, Worldmark-6, Asset Area LP-1B-03, Aerocity, Near IGI Airport, New Delhi.


Sir,

Please refer your online application ID No. 2026071409805 dated 15/07/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 01/08/2026 in the presence of **Sh. Ajitesh, Assistant Project Manager** and following shortcoming was observed: -

1. Width of Door provided 1.08 mtr. against the required width of 1.50 mtr .

Keeping in view of the above **shortcomings**, the application for issuance of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s Blue Tokai Coffee Roasters (A Unit of Muhavra Enterprises Pvt. Ltd.), Unit No. M17, Ground Floor, Worldmark-6, Asset Area LP-1B-03, Aerocity, Near IGI Airport, New Delhi.