



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001



C155

No. F.6/DFS/MS/GH/2025/NDZ/ 567

Dated: 19/12/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Bombay Orient (Guest House) located at 941-943 and 945-949 Matia Mahal, Jama Masjid, Delhi-110006, comprised of Ground plus three upper floors, (Ground floor- Reception & 17 Guest Rooms, 1st floor-20 Guest Rooms, 2nd floor-21 Guest Rooms & 3rd floor-21 Guest rooms, Total 79 Guest Rooms) owned/occupied M/s Bombay Orient (Guest House) was earlier granted FSC by this department vide letter no. F.6/DFS/MS/GH/NDZ/2022/511 dated 17/11/2022. The premises was re-inspected by the officer concerned of this department on 05/12/2025 in the presence of Mrs. Zeba Akram (Owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class "Residential" Sub- Division-A-1 with effect from 19/12/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....19/12/2025.....at New Delhi by



(Dr. S. K. TOMAR)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

o/c

To,

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. M/s Bombay Orient (Guest House) located at 941-943 and 945-949 Matia Mahal, Jama Masjid, Delhi-110006

MCD online ID 2025112415087

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/48

1. Name & address of the building : **M/s Bombay Orient at 941-943 and 945-949, Matia Mahal, Jama Masjid, Delhi-110006**
2. Type of Occupancy : Residential, Sub Division-A-1 (Guest House)
3. Building is comprised of : Ground + 03 upper floors,
Ground floor (Reception & 17 Guest Rooms), 1st floor (20 Guest Rooms), 2nd floor (21 Guest Rooms) & 3rd floor (21 guest rooms), Total 79 Guest rooms.
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/GH/NDZ/2022/511 dated 17/11/2022
6. Fire Safety directive letter No : Nil
7. Date of Inspection : 05/12/2025
8. Name of the Inspecting officers : Deepak Kumar, ADO (Shd.)
9. Name and designation of Officer from the building side : Mrs. Zeba Akram (Owner)
10. Year of Construction : 1992
11. Applicant's letter No : 2025112415087 dated 24/11/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessibility	06 m	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	02 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	0.80 m	1.09 m & 1.25 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A	N/A	N/A
		Required	Provided Natural	MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • types • ISI marking 	12 nos.	30 nos.	MR
		ABC/CO ₂	ABC/CO ₂	MR
		Required	Provided	MR

2.

06	First-aid-Hose Reels.			
	Total numbers on each floor	02 No.	02 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors CO	Required	Provided	MR
	• Location of main panel	Ground floor	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Each floor	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 Lpm.	450 Lpm.	MR
	➤ Head of the Pump	30mtr.	30mtr.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Rules. The FSC issued vide letter No. F.6/DFS/MS/GH/NDZ/2022/511 dated 17/11/2022 renewal under rule 37 of the Delhi Fire Service Rule, 2010 is recommended.

Last date:-23/12/2025

Deepak
06/12/2025

Signature of the Inspecting Officer

Name :- Deepak Kumar

Designation :- A.D.O (Shd)

~~DO (CD)~~ *[Signature]*
09/12/25

Dy. CFO (NDZ) *[Signature]*
10/12/25

Principal Director *[Signature]*
11/12/25

Dy. CFO (NDZ) *[Signature]*
17/12/25

~~ADOC (Shd)~~
pl. Sir, F.T. letter is put up for your kind signature

DY. CFO (NDZ) *[Signature]*
17/12/25

Deepak
16/12/2025